

PLANNING & DEVELOPMENT DEPARTMENT FOR THE CITY OF EASLEY

Post Office Box 466, 205 North 1st Street, Easley, SC 29641 • Office (864) 855-7908 Fax (864) 855-7951

TEMPORARY PERMANENT POWER INSPECTION CHECKLIST

Drywall must be hung.
Meter can be installed.
Must have 2 ½" conduit from bottom of meter can for underground power; conduit must be 18" below final grade. For overhead service, weather head must be installed; if above roofline, conduit must be rigid.
Must have 2 copper ground rods – minimum of 6' apart.
Must have at least one of the following circuits completed----washing machine, refrigerator.
Completed circuit consists of breaker being installed and GFI receptacle installed.
Cover must be installed on panel.
Incomplete circuits cannot have breakers installed.

Courtesy of Planning & Development department, POB 466, 205 North 1st Street, Easley, SC 29641..Office-855-7908...Fax-855-7951

This checklist is in no way to be considered as an all-inclusive checklist.

